## SAN DIEGO UNIFIED SCHOOL DISTRICT DRINKING WATER SAMPLING

| Site: Supply Center         | 7-Aug-17   |
|-----------------------------|--|
| Sampler SDUSD-Safety Office | Analyzed by:Enviromatrix Labs17G0819 Supply Center |

| Sample ID | Sample Date | Sample Location            | Lead result | Units | Type of Fixture        |
|-----------|-------------|----------------------------|-------------|-------|------------------------|
| 1         | 27-Jul      | Bldg K                     | 6           | ug/l  | water cooler northeast |
| 2         | 27-Jul      | Bldg K- break room         | ND          | ug/l  | sink faucet, northeast |
| 3         | 27-Jul      | Bldg K Food Service Office | 11          | ug/l  | drinking fountain      |
| 4         | 27-Jul      | Bldg N                     | ND          | ug/l  | sink faucet            |
| 5         | 27-Jul      | Bldg B                     | ND          | ug/l  | sink faucet            |
| 6         | 27-Jul      | Bldg M- break room         | ND          | ug/l  | sink faucet            |
|           | 3 1         |                            |             |       |                        |
|           |             |                            |             |       |                        |
|           |             |                            |             |       |                        |
|           |             |                            |             |       |                        |
|           |             |                            |             |       |                        |
|           | 8           |                            |             |       |                        |