

Water Quality Chemistry Services
 Lead School Testing
 Report Date: 28-Apr-2017

San Diego Unified School District
Arroyo Paseo High School

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168022	4/22/2017	6:12 AM	SAMPLE 1	3710020-AIJ-A	< 5	µg/L
W1168023	4/22/2017	6:04 AM	SAMPLE 2	3710020-AIJ-B	< 5	µg/L
W1168024	4/22/2017	6:08 AM	SAMPLE 3	3710020-AIJ-C	< 5	µg/L
W1168025	4/22/2017	6:09 AM	SAMPLE 4	3710020-AIJ-D	< 5	µg/L
W1168026	4/22/2017	6:06 AM	SAMPLE 5	3710020-AIJ-E	< 5	µg/L

<u>Source</u>	<u>Source Description</u>
SAMPLE 1	Main classroom building, north exterior wall, triple fountain, left bubbler
SAMPLE 2	Main building, room 18, bubbler at sink
SAMPLE 3	Main building, room 17, bubbler at sink
SAMPLE 4	Main building, room 14, bubbler at sink
SAMPLE 5	Main building, room 13, bubbler at sink

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist