



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A. San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/23/17

San Diego Unified School District  
**Innovations Academy**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168781	05/12/17		SAMPLE 1	3710020-BCG-A	< 5	ug/L
W1168782	05/12/17		SAMPLE 2	3710020-BCG-B	< 5	ug/L
W1168783	05/12/17		SAMPLE 3	3710020-BCG-C	< 5	ug/L
W1168784	05/12/17		SAMPLE 4	3710020-BCG-D	< 5	ug/L
W1168785	05/12/17		SAMPLE 5	3710020-BCG-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1      Outside 400 bldg. RRs, three single-bubbler fountains, center fountain
- SAMPLE 2      400 bldg, Inside room 402, left side of room, bubbler at sink
- SAMPLE 3      300 bldg, Outside near girls RR and wheel chair symbol, two single-bubbler fountains, lower right fountain
- SAMPLE 4      600 bldg, next to girls RR, three single-bubbler fountains, center fountain
- SAMPLE 5      700 bldg, Inside room 703, bubbler at sink

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist