



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A, San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/23/17

San Diego Unified School District  
**Jerabek Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1169355	05/12/17	06:00 AM	SAMPLE 1	3710020-BDE-A	< 5	ug/L
W1169356	05/12/17	06:08 AM	SAMPLE 2	3710020-BDE-B	< 5	ug/L
W1169357	05/12/17	06:11 AM	SAMPLE 3	3710020-BDE-C	< 5	ug/L
W1169358	05/12/17	06:14 AM	SAMPLE 4	3710020-BDE-D	< 5	ug/L
W1169359	05/12/17	06:20 AM	SAMPLE 5	3710020-BDE-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1    Outside near door to MPR, two single-bubbler fountains, lower left fountain
- SAMPLE 2    Outside bungalow restrooms next to B-1, two triple bubbler fountains, left fountain left bubbler
- SAMPLE 3    500 bldg, at wall near Red playground, two single-bubbler fountains, lower left fountain
- SAMPLE 4    400 bldg, Outside wall near blue playground equipment, triple bubbler fountain, right bubbler
- SAMPLE 5    Kindergarten bldg, Outside wall near kinder playground, two single-bubbler fountains, upper right fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist