



Environmental Monitoring and Technical Services  
2392 Kincaid Road MS 45A. San Diego, CA 92101  
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services  
Lead School Testing  
Report Date: 5/23/17

San Diego Unified School District  
**Lafayette Elementary**

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1171635	05/09/17	06:16 AM	SAMPLE 1	3710020-BGC-A	< 5	ug/L
W1171636	05/09/17	06:09 AM	SAMPLE 2	3710020-BGC-B	< 5	ug/L
W1171637	05/09/17	06:03 AM	SAMPLE 3	3710020-BGC-C	< 5	ug/L
W1171638	05/09/17	05:59 AM	SAMPLE 4	3710020-BGC-D	< 5	ug/L
W1171639	05/09/17	06:06 AM	SAMPLE 5	3710020-BGC-E	< 5	ug/L

**Source**      **Source Description**

- SAMPLE 1      Kindergarten bldg, Inside K-5, bubbler at sink
- SAMPLE 2      Kindergarten bldg, play area between K-3 & K-4 (exterior north facing wall), two single bubbler fountains, lower left fountain
- SAMPLE 3      Classrooms 1-6 bldg, Exterior north wall between boy & girl's RR, three single bubbler fountains, middle fountain
- SAMPLE 4      Kitchen, Interior north wall next to ovens, spray nozzle above 2-compartment sink
- SAMPLE 5      Classrooms 7-12 bldg, South exterior wall near storage room & custodian room 3, triple bubbler fountain, left bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L  
Action Level (AL) = 15 ug/L

  
Doug Campbell, Senior Chemist