



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/27/17

San Diego Unified School District
O'Farrell Charter

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166841	04/15/17	06:15 AM	SAMPLE 1	3710020-AFE-A	< 5	ug/L
W1166842	04/15/17	06:05 AM	SAMPLE 2	3710020-AFE-B	< 5	ug/L
W1166843	04/15/17	06:02 AM	SAMPLE 3	3710020-AFE-C	< 5	ug/L
W1166844	04/15/17	05:57 AM	SAMPLE 4	3710020-AFE-D	< 5	ug/L
W1166845	04/15/17	06:11 AM	SAMPLE 5	3710020-AFE-E	< 5	ug/L

<u>Source</u>	<u>Source Description</u>
SAMPLE 1	BLDG 400, between outside restrooms, upper right bubbler
SAMPLE 2	Cafeteria/staff lounge, triple fountain, middle bubbler
SAMPLE 3	Kitchen, single compartment sink, faucet
SAMPLE 4	BLDG 503 front, outside 3 fountains, middle fountain bubbler
SAMPLE 5	BLDG 300; adjacent to rooms 101 and 102, outside batrooms, upper right bubbler

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Tom Burger, Associate Chemist