



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A, San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 4/27/17

San Diego Unified School District
Penn Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1166093	04/12/17	06:09 AM	SAMPLE 1	3710020-ADJ-A	< 5	ug/L
W1166094	04/12/17	06:15 AM	SAMPLE 2	3710020-ADJ-B	< 5	ug/L
W1166095	04/12/17	06:22 AM	SAMPLE 3	3710020-ADJ-C	< 5	ug/L
W1166096	04/12/17	06:18 AM	SAMPLE 4	3710020-ADJ-D	< 5	ug/L
W1166097	04/12/17	06:26 AM	SAMPLE 5	3710020-ADJ-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 Library/multi purpose, Kitchen, faucet at single compartment deep sink, faucet (235-01)
- SAMPLE 2 Rooms 02-06 bldg, exterior wall of girls resroom, facing B-7, triple fountain, left bubbler (235-02)
- SAMPLE 3 Portable classrooms, exterior wall at room B-3, two tripple fountains, left bubbler on right triple (235-03)
- SAMPLE 4 Rooms 02-05 bldg, exterior wall of girls restroom, facing B-7, triple fountain, right bubbler (235-04)
- SAMPLE 5 Rooms 02-04 bldg, exterior wall of girls restroom, facing B-12, triple fountain, left bubbler (235-05)

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Doug Campbell, Senior Chemist