

Water Quality Chemistry Services
 Lead School Testing
 Report Date: 28-Apr-2017

San Diego Unified School District
Sherman Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1167419	4/20/2017	6:02 AM	SAMPLE 1	3710020-AGI-A	< 5	µg/L
W1167420	4/20/2017	6:07 AM	SAMPLE 2	3710020-AGI-B	< 5	µg/L
W1167421	4/20/2017	6:13 AM	SAMPLE 3	3710020-AGI-C	< 5	µg/L
W1167422	4/20/2017	6:16 AM	SAMPLE 4	3710020-AGI-D	< 5	µg/L
W1167423	4/20/2017	6:21 AM	SAMPLE 5	3710020-AGI-E	< 5	µg/L

<u>Source</u>	<u>Source Description</u>
SAMPLE 1	Kinder play area outside of room #3, three single bubbler fountains, middle fountain
SAMPLE 2	outside in lunch area, three single bubbler fountains, right fountain
SAMPLE 3	Outside of room #12 left of boys RR, three single bubbler fountains, right fountain
SAMPLE 4	Outside of room #28 left of boys RR, three single bubbler fountains, middle fountain
SAMPLE 5	Outside of room # 21 (second floor), three single bubbler fountains, middle fountain

DRL=State Mandated Detection Limit for Reporting (DLR)= 5 µg/L
 Action Level (AL) = 15 µg/L



Doug Campbell, Senior Chemist