



Environmental Monitoring and Technical Services
2392 Kincaid Road MS 45A. San Diego, CA 92101
Tel(619) 758-2300 Fax (619) 758-2309

Water Quality Chemistry Services
Lead School Testing
Report Date: 5/4/17

San Diego Unified School District
Walker Elementary

Sample ID	Sample Date	Sample Time	Source	External ID	Lead	Units
W1168332	04/26/17	06:13 AM	SAMPLE 1	3710020-BBH-A	< 5	ug/L
W1168333	04/26/17	06:10 AM	SAMPLE 2	3710020-BBH-B	< 5	ug/L
W1168334	04/26/17	06:07 AM	SAMPLE 3	3710020-BBH-C	< 5	ug/L
W1168335	04/26/17	06:03 AM	SAMPLE 4	3710020-BBH-D	< 5	ug/L
W1168336	04/26/17	06:28 AM	SAMPLE 5	3710020-BBH-E	< 5	ug/L

Source **Source Description**

- SAMPLE 1 bldg 12-16, Inside rm 14 at back of room in 3-C room, Bubbler drinking fountain at sink
- SAMPLE 2 bldg 11-16, Inside classroom 13 at back of room inside 3-D, bubbler at sink
- SAMPLE 3 Kitchen/Lunch Area, Outside near lunch court at kitchen wall, three-bubbler fountain, left bubbler
- SAMPLE 4 bldg 31-36, near black top playground closest to red play equipment, two single-bubbler fountains, lower left fountain
- SAMPLE 5 CC bldg, outdoor hallway on left wall between boys and girls RRs, two single-bubbler fountains to the left of triple bubbler fountain, lower left single fountain

DLR= State Mandated Detection Limit for Reporting (DLR)= 5 ug/L
Action Level (AL) = 15 ug/L


Tom Burger, Associate Chemist